



SAMPLE NOT COLLECTED
BY UNIT STAFF

WATER QUALITY MONITORING UNIT
AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI
QUALITY CONTROL & TECHNICAL AUDIT CELL
NEW DELHI MUNICIPAL COUNCIL
ISO 9001-2015 CERTIFIED

1. Name & Address of Sender:- *principal, St. Columba's school, Ashok place, New Delhi.*
2. Date of Receiving/Collection:- *22-08-2022,*
3. Sample No.:- *8605-8607.*
4. Sealed Sample (Yes/No):-

DRINKING WATER TESTING REPORT
TEST-RESULTS

Sr. No.	Location, Date & Time of Sample (Collection Site)	Colour (Pt-Co Scale)	Taste & Odour	Turbidity (NTU)	pH	Total Hardness (as CaCO ₃) (Mg/L)	TDS (Mg/L)	Iron (as Fe) (Mg/L)	Chloride (as Cl) (Mg/L)	Residual free Chlorine (Mg/L)	Coliform org. MPN / (100 ML)	E.Coli MPN/ 100 ML
1. 'A'	<i>Junior school</i>	5	<i>Agreeable</i>	0.3	8.0	90	121	0.09	24	NIL	NIL	—
2. 'B'	<i>Middle school</i>	5	<i>do</i>	0.2	8.1	92	122	0.08	24	NIL	NIL	—
3. 'C'	<i>Senior school</i>	<5	<i>do</i>	0.2	8.1	14	30	0.04	12	NIL	NIL	—
4.												
5.												
BIS: 10500 2012	Acceptable Limits	05 max	Agree able	1 max.	6.5 To 8.5	200 max.	500 max.	0.3 max.	250 max.	0.2 min.	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agree able	5	No relaxa tion	600	2000	No relaxa tion	1000	1	NIL	NIL

Remarks:- With respect to above tests, all the above water samples ~~except Sr. No. _____~~ ~~can/cannot~~ be considered fit for drinking purposes. However minimum residual free chlorine 0.2 Mg/L should be done to avoid contamination.

Vedant
24/8/22
Chemist/Lab. Technician

Prerna
24/8/22
Lab. Technician/Asstt.

- Note:-**
- 1) water samples will be destroyed after testing unless otherwise specified by party.
 - 2) If the sample is not collected by our WQMU staff, the sender/party will be responsible for any wrong, incomplete or misleading information given by him.
 - 3) This test report is not valid for any legal proceeding.