

WATER QUALITY MONITORING UNIT AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI QUALITY CONTROL & TECHNICAL AUDIT CELL NEW DELHI MUNICIPAL COUNCIL ISO 9001-2015 CERTIFIED

AMPLE NOT CULLEG L BY UNIT STAFF

1. Name & Address of Sender:- poincipal, St. Columba's 3chowl, ASKO/ 2. Date of Receiving/Collection:- 03-08-2023 . Place, NED Belhi

- 3. Sample No.:- 8034 8037
- 4. Sealed Sample (Yes/No):-

, ¹

`,"

DRINKING	WATER	TESTING	REPORT
	TEST-R	ESULTS	

Sr. No.	Location, Date & Time of Sample Collection Site	Colour (Pt-Co Scale)	Taste & Odour	Turbidity (NTU)	P"	Total Hardness (as CaCO ₃) (Mg/L)	TDS (Mg/L)	Iron (as Fe) (Mg/L)	Chloride (as C1) (Mg/L)	Residual free Chlorine (Mg/L)	Coliform org. MPN / (100 ML)	E.Coli MPN/ 100 ML
1. 'B'	Junior School	5	mereste	0.2	7.6	100	147	0-17	40	NIL	NIL	-
2. 'C'	middle School	5	-do-	0.2	7.7	90	132	0.18	36	NIL	NIL	-
з. ~Д	Middle Schoul, Cassend	5	-do-	0.3	7 .6	100	146	0.17	40	NIL	NIL	_
4. E	senior school	5	-do-	0.2	7-6	90	132	0.16	34	NIL	NIL	
5.												
BIS: 10500 2012	Acceptable Limits	05 max	Agree / able	1 max.	6.5 To 8.5	200 тах.	500 max.	0.3 max.	250 max.	0.2 min.	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agree able	5	No relaxa tion	600	2000	No relaxa tion	1000	1	NIL	NIL

Jeen 8123

Chemist/Lab. Technician

Lab. Technician/Anth

- Note:- 1) water samples will be destroyed after testing unless otherwise specified by party.
 - If the sample is not collected by our WQMU staff, the sender/party will be responsible for any wrong, incomplete or misleading information given by him.
 - 3) This test report is not valid for any legal proceeding.