

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**


No.F6/DFS/MS/School/NDZ/2024/ 50

Dated:- 23/01/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **ST. Columba's School** located at **Ashoka Place, New Delhi** comprises of **Middle School Block - B + Gr. + 2 Floors, Sr. Sec. School Block – Gr. + 01 upper floor, Edmund Rice Hall Block – B + Gr. & Jr. Block- Gr. + 02 floors** was earlier granted FSC by this department vide letter No. **F6/DFS/MS/School/NDZ/2020/410 dated 08/10/2020**. Now, the premises was re-inspected by the officer concerned of this department on 11-01-2024 in the presence of **Mrs. Renu Rana** and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class **Group B "Educational Building" (Sub-Div. B-I)** with effect from **23.01.2024** for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on **23.01.2024** at New Delhi by.

  
**(Atul Garg)**  
DIRECTOR  
Delhi Fire Service

**Copy to:-**

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. Director of Education, Govt. of NCT, Delhi.
3. The Principal, St. Columba's School, Ashoka Place, New Delhi.

**Conditions for the validity of fire safety certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. The trained fire fighting staff should be available round the clock.
6. Basement shall be used as per NBC/BBL 1983.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration shall strictly be prohibited.