



WATER QUALITY MONITORING UNIT
AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI
QUALITY CONTROL & TECHNICAL AUDIT CELL
NEW DELHI MUNICIPAL COUNCIL
ISO 9001-2015 CERTIFIED

SAMPLE NOT COLLECTED
BY UNIT STAFF

1. Name & Address of Sender:- *Principal, St. Columba's School, Ashoka Place, New Delhi.*
2. Date of Receiving/Collection:- *07-08-2024.*
3. Sample No.:- *8180-8183*
4. Sealed Sample (Yes/No):-

DRINKING WATER TESTING REPORT
TEST-RESULTS

Sr. No.	Location, Date & Time of Sample Collection Site	Colour (Pt-Co Scale)	Taste & Odour	Turbidity (NTU)	pH	Total Hardness (as CaCO ₃) (Mg/L)	TDS (Mg/L)	Iron (as Fe) (Mg/L)	Chloride (as Cl) (Mg/L)	Residual free Chlorine (Mg/L)	Coliform org. MPN / (100 ML)	E.Coli MPN/ 100 ML
1.	<i>A</i> CH-1	5	<i>Agreeable</i>	0.7	7.4	128	223	0.24	76	NIL	NIL	—
2.	<i>B</i> CH-2	5	<i>Agreeable</i>	0.4	7.6	102	177	0.18	60	NIL	NIL	—
3.	<i>C</i> VM-1	5	<i>Agreeable</i>	0.6	7.6	118	205	0.21	70	NIL	NIL	—
4.	<i>D</i> VM-2	5	<i>Agreeable</i>	0.4	7.5	114	198	0.20	66	NIL	NIL	—
5.												
BIS: 10500 2012	Acceptable Limits	05 max	Agreeable	1 max.	6.5 To 8.5	200 max.	500 max.	0.3 max.	250 max.	0.2 min.	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agreeable	5	No relaxation	600	2000	No relaxation	1000	1	NIL	NIL

Remarks:- With respect to above tests, all the above water samples ~~except~~ Sr. No. ----- can ~~cannot~~ be considered fit for drinking purposes. However minimum residual free chlorine 0.2 Mg/L should be done to avoid contamination.

10/08/24

Chemist/Lab. Technician

Praveen
10/08/24
Lab. Technician/Asstt.

- Note:-**
- 1) water samples will be destroyed after testing unless otherwise specified by party.
 - 2) If the sample is not collected by our WQMU staff, the sender/party will be responsible for any wrong, incomplete or misleading information given by him.
 - 3) This test report is not valid for any legal proceeding.