



WATER QUALITY MONITORING UNIT AMRIT BHAWAN, VINAY MARG, CHANAKYAPURI QUALITY CONTROL & TECHNICAL AUDIT CELL NEW DELHI MUNICIPAL COUNCIL ISO 9001-2015 CERTIFIED

1. Name & Address of Sender: - principal, St. columba's school

2. Date of Receiving/Gollection: 17-02-2025,

3. Sample No.:- 1229 1200

3. Sample No.:- 1279 - 1282

4. Sealed Sample (Yes/No):-

DRINKING WATER TESTING REPORT

TEST-RESULTS

TEST-RESULTS												
Sr. No.	Location, Date & Time of Sample Collection Site	Colour (Pt-Co Scale)	Taste & Odour	Turbidity (NTU)	P	Total Hardness (as CaCO ₂) (Mg/L)	TDS (Mg/L)	Iron (as Fe) (Mg/L)	Chloride (as C1) (Mg/L)	Residual free Chlorine (Mg/L)	Coliform org. MPN / (100 ML)	E.Coli MPN/ 100 ML
1.	St. Columb School [1]	5	Many	0.3	7.8	146	252	0-16	86	NIL	MIL	-
2. 'B	School [2]	5	A relable	0.3	7-8	156	270	0.18	86	NIL	NIL	_
3.	St-Lolumba School [3]	5	gresser		7.7	154	2 66	0-18	90	NIL	NIL	_
4. 'ø'	St. Columbas School [4]	5	Market	0-7	7.8	142	246	0.15	94	NIL	NIL	_
5.												
BIS: 10500 2012	Acceptable Limits	тах 05	Agree able	1 max.	6.5 To 8.5	200 max.	500 max.	0.3 max.	250 max.	0.2 min.	NIL	NIL
	Permissible Limits (in the absence of alternate source.)	15	Agree able	5	No relaxa tion	600	2000	No relaxa tion	1000	1	NIL	NIL

considered fit for drinking purposes. However minimum residual free chlorine 0.2 Mg/L should be done to avoid contamination.

Chemist/Lab. Technician

Note:- 1) water samples will be destroyed after testing unless otherwise specified by party.

- 2) If the sample is not collected by our WQMU staff, the sender/party will be responsible for any wrong, incomplete or misleading information given by him.
- 3) This test report is not valid for any legal proceeding.